

Resistive Thermal Energy Storage an Electricity Storage Alternative for the Australian Grid

C.-A. Asselineau, M. Venkataraman, W. Lipinski and J. Pye

Charles-alexis.asselineau@anu.edu.au

Solar Thermal Group, Research School of Engineering


The Australian National University

- Context: Large scale electricity storage
- Resistive Thermal Energy Storage (RTES)
 - Technology
 - Levelised Cost Of Storage (LCOS) benchmark
 - Sensitivity analysis
 - Resistive heater design
- Conclusions and outlook


Context: large scale storage

- Incoming cheap renewable energy!

“Renewable Power Generation Costs in 2017”, IRENA, 2017




“Electricity Storage and Renewables: Costs and Markets to 2030”, IRENA, 2017



- IRENA, 2017: doubling of VRES penetration
 - Electricity storage grows 155 - 227% from 2017 to 2030
 - 96% Pumped-Hydro Electricity Storage (PHES):
 - Open-loop: 320 plants operational, 167.9 GW, energy capacity unknown.
 - Closed-loop: 2 plants operational, 2.1 GW, 10.8 GWh (DOE database)
 - 1.9% Thermal Energy Storage (TES):
 - 75% of Molten Salt thermal Storage (CSP plants): 2.5 GW, 17.5 GWh (DOE database)
 - 1.1% Batteries:
 - Total capacity: 1.9 GW, ~3.5 GWh (DOE database)



RTES: Technology



- Context: Large scale electricity storage
- Resistive Thermal Energy Storage (RTES)
 - Technology
 - Levelised Cost Of Storage (LCOS) benchmark
 - Sensitivity analysis
 - Resistive heater design
- Conclusions and outlook

- Characteristics:


- Turbine startup time: ~30 min
- Charging efficiency: 97%
- Thermal storage efficiency: 99%
- Power block net efficiency: 37.1 %
- Round-trip efficiency: 35.6%

- Mature engineering components:

- Stainless steel tanks and piping
- Steam turbine
- Air-cooled condenser
- Heat exchanger

- New component:

- Large scale molten-salt resistive heater




RTEs: LCOS benchmark

- Benchmark:
 - Lazard Levelised Cost of Storage 2.0 (2016)
- Transmission level:
 - 8 hours of storage
 - 100 MW power output
 - 350 days of operations/year
 - 1 cycle of full discharge/day
 - Cost of electricity **35 USD/MWh**
 - LCOS: ($\$/\text{kWh}_e$ delivered)

LAZARD'S LEVELIZED COST OF STORAGE—VERSION 2.0

LAZARD



Commercially available


Compressed Air	\$116	\$140	
Flow Battery(V)	\$314		\$690
Flow Battery(Zn)		\$434	\$549
Flow Battery(O)	\$340		\$630
Lithium-Ion ^(a)	\$267		\$561
Pumped Hydro	\$152	\$198	
Sodium ^(b)	\$301		\$784
Thermal	\$227	\$280	
Zinc	\$262		\$438

- RTES costing assumptions:
 - NREL System Advisor Model (SAM) cost breakdown for CST
 - Remove the Capital cost of the heliostat field and tower
 - Keep the full cost of the balance of plant (BOP)
 - 2 cost scenarios for the resistive heater and the power block:
 - High cost: the switch to resistive heating represents a doubling of the cost of the BOP of the reference CST system.
 - Low cost: the switch to resistive heating is negligible when compared with the cost of the BOP of the reference CST system.

	High cost	Low cost
Cost of thermal storage (USD/kWh _{th})		24
Cost of BOP (USD/kWh _e)		340
Cost of resistive heating (USD/kWh _e)	340	0
Cost of power block (USD/kWh _e)	1100	1000
EPC and owner cost ratio		0.13




RTES: LCOS benchmark




RTES: Sensitivity analysis

- Cost of electricity: 8.8 – 61 USD/MWh




- Storage volumes: 1 to 14 hours (100 MWe)




- Context: Large scale electricity storage
- Resistive Thermal Energy Storage (RTES)
 - Technology
 - Levelised Cost Of Storage (LCOS) benchmark
 - Sensitivity analysis
 - Resistive heater design
- Conclusions and outlook

- Preliminary and conservative cost estimations look very promising
- Aspects not considered yet:
 - Arbitrage:
 - Start-up time of the steam turbine is ~30 min with the current technology
 - Power regulation on both charge and discharge
 - Very small footprint and site independent:
 - Low project risks
 - Low environmental impacts
 - Transmission loss is greatly reduced
 - Can be installed at the substation level for local grids
 - Life cycle potential:
 - Solar salt is a fertiliser at the end of the plant life
 - Most of the plant is steel and can be recycled



- Develop preliminary designs:
 - Molten-salt film temperature $< 595^{\circ}\text{C}$
 - Flow velocity $< 3\text{ m/s}$
 - Operation range from 290°C to 565°C



- Refine costing and preliminary design:
 - Assess the cost reductions compared to the CST system such as: BOP, resistive heater, O&M, turbine size.
- Integration with CST:
 - Oversized storage with resistive charger
 - Compare the charging cost with CST, grid, PV and wind.
- System integration case studies including grid dynamics:
 - Electricity pricing variability
 - Isolated grid with high VRE penetration
- Progress in high-temperature ($> 700^{\circ}\text{C}$) storage
 - More efficient generation using sCO_2 Brayton cycle: from 37% to 50% power block efficiency.
 - Higher storage density and lower costs

Thank you

Charles-Alexis Asselineau

e charles-alexis.asselineau@anu.edu.au

w <http://stg.anu.edu.au/>

Annex: financial parameters

Technical Operating Parameters and Specifications	Value_orig
Design Storage Capacity (kWh-e)	800000
Design Power Output (kW-e)	100000
Storage Hours (h)	8
Days of Operation in a year	350
Annual Storage Capacity	280000000
Reference year	2017
Assumed start-up year	2020
Basis year	2015
Plant life (years)	20
Analysis period (years)	20
Depreciation Schedule Length (years)	20
Discount Rate	8.00%
Debt period (years)	20
Salvage value (% of total capital investment)	10.00%
Inflation rate (%)	1.90%
After-tax Real IRR (%)	0.00%
Taxes	38.90%
Site Prep	0.00%
Services	18.00%
Contingencies and contractor fee	0.00%
Land Cost	2.00%
Startup cost	10.00%
Number of operators	4
Annual Wages	139000
Insurance	2.00%
OandM	1.50%
Electricity cost per kWh	0.035