



# Energy flexibility for water cooperations

December 2023

Solar Energy Application Lab

School of PCPM, RMIT

Kaige Wang


Rebecca Yang; Kazi Hasan; Jiatong Zhang; Chengyang Liu; Xun Yi; Fengling Han; Gary Rosengarten; Ron Wakefield;

# Project partners



# Background – RE transition in power systems


Australian electricity generation renewable sources




Source: DCCEEW (2023) Australian Energy Statistics

- RES are essential and inevitable for future power systems.
- Wind and solar penetration has increased considerably worldwide in last decades.
- Australian renewables generation has increased 215% from 2012 to 2022 (fig 1).

# High RE penetration challenges



Source: AEMO (2020) Energy Explained: Frequency



# To mitigate the imbalance...



Demand response is an effective method to balance electricity supply and demand.



Changes in electric use from demand side in response to the variation of electricity price or power system reliability.



Large flexible demand users, such as water utilities, have higher potential to provide demand response.

# Why water utilities?



Large energy demand and carbon emissions



Ambitious net zero carbon targets



Abundant on-site renewable generation



Surrounded by DERs communities




Vast load flexibility

# Research aim and main tasks

This project aims to support the water corporation in achieving their net-zero targets through exploring the potential of community-based distributed generators and load management & renewable energy strategies.



Energy and cost efficiency benefits of adopting load management strategies for water utility




The potential of integrating renewable generation, storage and trading options



Decision-making of optimal energy strategies from both technical and economic perspectives

# Demand response programs in Australia





# Flexibility in water utilities

## Flexibility and RE options

**Load flexibility:** *Aeration, Water pumping, etc.*

**On-site energy storage:** *Battery, Biogas storage, PSH, etc.*

**On-site generation:** *Solar PV, Biogas, Hydropower*

**Neighbouring DERs:** *Rooftop PV, Distributed Battery system*

# RE and Load Management analyses matrix

Flexibility and RE options Demand response options		R0: Load flexibility On-site generation	R1: Load flexibility On-site generation On-site energy storage	R2: Load flexibility On-site generation Neighbouring DERs	R3: Load flexibility On-site generation Neighbouring DERs On-site energy storage
		Price-based DR		Retailer contract (TOU) TOU-R0	TOU-R1
		Spot market (RTP) RTP-R0	RTP-R1	RTP-R2	RTP-R3
Incentive-based DR		NEM-FCAS demand response (FCAS) FCAS-R0	FCAS-R1	FCAS-R2	FCAS-R3
		NEM-Wholesale demand response (NEM-W) NEM-W-R0	NEM-W-R1	NEM-W-R2	NEM-W-R3
		Emergency demand response (RERT) RERT-R0	RERT-R1	RERT-R2	RERT-R3

Demand response modelling

DER modelling and options

Community energy trading

Reinforcement learning

Technoeconomic analysis

Modelling and optimization methods

# Coliban Water Sites selection

## Epsom WWTP

- 2 Bluefish Dr, Manly NSW 2095

## Echuca WWTP

- Hugh Bamford Reserve, North Bondi NSW 2026

## Kyneton WWTP

- 1 Fishermans Rd, Malabar NSW 2036

## Rochester WWTP

- 380-420 Captain Cook Dr, Greenhills Beach NSW 2230



# Sydney Water Sites selection

## North Head WWTP

- 2 Bluefish Dr, Manly NSW 2095

## Bondi WWTP

- Hugh Bamford Reserve, North Bondi NSW 2026

## Malabar WWTP


- 1 Fishermans Rd, Malabar NSW 2036

## Cronulla WWTP

- 380-420 Captain Cook Dr, Greenhills Beach NSW 2230

## Liverpool WWTP

- 32-40 Scrivener St, Warwick Farm NSW 2170



# Case study: Bendigo (Epsom) Water Reclamation Plant

## DR + RE + P2P + BESS – Scenario R3

### Renewable energy option:

- PV and battery proposed
- On-site PV: 250 KW
- Battery:
  - Capacity: 250 kWh
  - Max output: 125 KW

### Existing load management plan:

FCAS agreement in place for 700 KVA (switching off the aerators)


### Consumption:

~ 1.2 MWh per hour

### Proposed load management options:


- Demand response
  - NEM: FCAS, WDR
  - Price-based DR: RTP (NEM spot market)
- P2P energy trading: 500 households with rooftop PV






# Economic analysis

- **Base case:** On-site PV
- **Optimised case:** On-site PV + DR + P2P + BESS
- **Cumulative cost reduction:** AUD 115,000 / year
- The total energy expenses were reduced by **13 %**
- **IBDR revenue:** AUD 54,000 / year
- **P2P energy trading expenses:** AUD 20,000 / year
- **Community Savings:** 16,500 / year





# Grid Import

- **Reduction on grid import : 500 MWh / year**
- **The total grid import was reduced by 5 %**





# DR participation



# Future work



Deploy training process with AWS  
Cloud Computing platform



Completing simulation and analysis  
for more case studies

# Energy flexibility for water cooperations

Solar Energy Application Lab